



Product Service

CERTIFICATE

No. B 133827 0001 Rev. 00

Holder of Certificate: Shaanxi Jinshenghong Cable Co., Ltd.

Room 607, Fortune Building
Sanqiao Sub-district, Fengdong New City
710086 Xixian New Area, Shaanxi Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Electric Cables

Electric cables for photovoltaic systems
with a voltage rating of 1,5kV DC

Model(s):

H1Z2Z2-K & 62930 IEC 131
1×1.5mm², 1×2.5mm², 1×4mm², 1×6mm²
1×10mm², 1×16mm², 1×25mm², 1×35mm²
2×1.5mm², 2×2.5mm², 2×4mm², 2×6mm²
2×10mm², 2×16mm²

Parameters:

Rated Voltage: DC 1.5 kV (between conductors and
between conductor and earth)
AC U₀/U: 1.0/1.0 kV
Class (IEC 61140): II
Ambient Temperature: -40°C ~+90°C
Max. Temperature
at conductor: 120°C

Tested according to:

EN 50618:2014
IEC 62930:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier.

All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.:

701262519501-00

Valid until:

2028-09-27

Date, 2025-09-12

(Yaqun Alex Liu)